



THIS HOME'S SCORE **9** OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

**\$1,300** PER YEAR

## HOME PROFILE

### LOCATION:

3265 SE Raymond St  
Portland, OR 97202

### YEAR BUILT:

2022

### HEATED FLOOR AREA:

2,573 sq.ft.

### NUMBER OF BEDROOMS:

4

## ASSESSMENT

### ASSESSMENT DATE:

06/02/2022

### SCORE EXPIRATION DATE:

06/02/2030

### ASSESSOR:

Tyler Moffet  
Moffet Energy Modeling

### PHONE:

916-342-0742

### EMAIL:

tylermoffet@  
moffetenergymodeling.com


### LICENSE #:

213474

*Flip over to learn how to improve this score and use less energy!*



## Home Energy Score



### Preliminary Assessment | ID# 387349

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at [HomeEnergyScore.gov](http://HomeEnergyScore.gov).

## HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

<b>Electric:</b> 8,198 kWh/yr.....	\$1,007
<b>Natural Gas:</b> 312 therms/yr.....	\$293
<b>Other:</b> .....	\$0
<b>Renewable Generation:</b> .....	(\$0)
<b>TOTAL ENERGY COSTS PER YEAR</b>	<b>\$1,300</b>

**How much renewable energy does this home generate?**

\_\_\_\_\_ kWh/yr

## THIS HOME'S CARBON FOOTPRINT:



What should my home's carbon footprint be? Between now and 2030, Portlanders should reduce carbon pollution per household to 3 metric tons per year to reach our climate goals.

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices (\$0.12/kwh for electricity; \$0.94/therm for natural gas; \$2.78/gal for heating oil; \$2.52/gal for propane).
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- Relisting 2-7 years after the assessment date requires a free reprint of the Report from [us.greenbuildingregistry.com](http://us.greenbuildingregistry.com) to update energy and carbon information.
- **This report meets Oregon's Home Energy Performance Score Standard and complies with Portland City Code Chapter 17.108.**

Score today:

9

Score with priority improvements:

9

Estimated energy savings with priority improvements:

\$0 PER YEAR

Estimated carbon reduction with priority improvements:

0% PER YEAR

## TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids. If a new home, discuss with the builder. Checkout [www.energytrust.org/findacontractor](http://www.energytrust.org/findacontractor) or call toll free **1-866-368-7878**.
- Explore financing options at [communityenergyproject.org](http://communityenergyproject.org) or [energytrust.org](http://energytrust.org).
- Visit the following resources to learn about easy changes you can make today: [communityenergyproject.org/our-services](http://communityenergyproject.org/our-services) or [energytrust.org/solutions/insulation-and-air-sealing/](http://energytrust.org/solutions/insulation-and-air-sealing/)

## PRIORITY ENERGY IMPROVEMENTS <sup>1</sup>

FEATURE

TODAY'S CONDITION<sup>4</sup>

RECOMMENDED IMPROVEMENTS<sup>3</sup>

## ADDITIONAL ENERGY RECOMMENDATIONS <sup>2</sup>

FEATURE

TODAY'S CONDITION<sup>4</sup>

RECOMMENDED IMPROVEMENTS

Solar PV	N/A	Visit <a href="http://www.energytrust.org/solar">www.energytrust.org/solar</a> to learn more
Air Conditioner	N/A	
Attic insulation	Ceiling insulated to R-49	
Basement wall insulation	N/A	
Cathedral Ceiling/Roof	None	
Duct insulation	Insulated	
Duct sealing	Sealed	
Envelope/Air sealing	Professionally air sealed	
Floor insulation	Insulated to R-30	
Foundation wall insulation	N/A	
Heating equipment	Natural gas furnace 96% AFUE	
Skylights	N/A	
Wall insulation	Insulated to R-21	
Water Heater	Natural gas on demand	
Windows	U value 0.27, SHGC value 0.3	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. If your home has an oil furnace it is recommended you replace it with a high efficiency electric heat pump.

4. Today's Condition represents the majority condition for that feature in the home.